



ÜNKA KABLO

UK  
CA

## Declaration of Performances (DoP)

No. UK2021009

Product Type

CY-YSLCY (300/500 V)

\* 2 to 34 core - 0,5 mm<sup>2</sup>  
\* 2 to 34 core - 1,5 mm<sup>2</sup>  
\* 2 to 5 core - 6 mm<sup>2</sup>  
\* 3 to 5 core - 25 mm<sup>2</sup>  
\* 3 to 4 core - 70 mm<sup>2</sup>

\* 2 to 34 core - 0,75 mm<sup>2</sup>  
\* 2 to 34 core - 2,5 mm<sup>2</sup>  
\* 2 to 5 core - 10 mm<sup>2</sup>  
\* 3 to 5 core - 35 mm<sup>2</sup>

\* 2 to 34 core - 1,00 mm<sup>2</sup>  
\* 2 to 7 core - 4 mm<sup>2</sup>  
\* 2 to 5 core - 16 mm<sup>2</sup>  
\* 3 to 5 core - 50 mm<sup>2</sup>

Batch or Serial Number

M1 4 XXX XXYYYYZZ

Intended use:

Supply of electricity in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke

### System 3

of assessment and verification of constancy of performance

### Approved laboratory body No. NB 2661

The performance of the product identified above is in conformity with the declared performance(s) This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, as its effect in the United Kingdom under the sole responsibility of the manufacturer identified above.

Reaction to fire:

**Eca**

Designated standard:

EN 50575 : 2014 + A1:2016

Dangerous Substances:

**NPD**

Manufacturer:

ÜNKA KABLO SAN. VE TİC. A.Ş  
Saray Mah.  
Ahmet Tevfik İleri Cad.  
No : 16/4  
Ümraniye / İstanbul / TURKEY

Signed for and behalf of the manufacturer by:

Barış TABAK / QA & QC Manager  
İstanbul, 11/08/2021

  
ÜNKA KABLO  
SANAYİ VE TİCARET A.Ş.  
ÜMRANIYE - İSTANBUL