



ÜNKA KABLO



## Declaration of Performances (DoP)

No. 20170003

Product Type

LIYCY (300/500 V)

\* 2 to 34 core - 0,5 mm<sup>2</sup>

\* 2 to 34 core - 0,75 mm<sup>2</sup>

\* 2 to 34 core - 1,00 mm<sup>2</sup>

\* 2 to 34 core - 1,5 mm<sup>2</sup>

\* 2 to 34 core - 2,5 mm<sup>2</sup>

\* 2 to 7 core - 4 mm<sup>2</sup>

\* 2 to 5 core - 6 mm<sup>2</sup>

\* 2 to 5 core - 10 mm<sup>2</sup>

\* 2 to 5 core - 16 mm<sup>2</sup>

\* 3 to 5 core - 25 mm<sup>2</sup>

\* 3 to 5 core - 35 mm<sup>2</sup>

\* 3 to 5 core - 50 mm<sup>2</sup>

\* 3 to 4 core - 70 mm<sup>2</sup>

Batch or Serial Number

M1 4 XXX XYZZZZ

Intended use:

Supply of electricity in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke

### System 3

of assessment and verification of constancy of performance

### Notified laboratory body No. NB 1014

The performance of the product identified above is in conformity with the declared performance(s) This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Reaction to fire:

**Eca**

Harmonized standard:  
EN 50575 : 2014 + A1:2016

Dangerous Substances:

**NPD**

Manufacturer:  
ÜNKA KABLO SAN. VE TİC. A.Ş  
Saray Mah.  
Ahmet Tevfik İleri Cad.  
No : 16/4  
Ümraniye / İstanbul / TURKEY

Signed for and behalf of the manufacturer by:  
Barış TABAK / QA & QC Manager  
İstanbul, 17/02/2017



This declaration of performance is issued under the sole responsibility of the manufacturer.