



ÜNKABLO

Declaration of Performances (DoP)

No. 20170011

Product Type

YY-YSLY (600/1000 V)

* 2 to 34 core - 0,5 mm²
* 2 to 34 core - 1,5 mm²
* 2 to 5 core - 6 mm²
* 3 to 5 core - 25 mm²
* 3 to 4 core - 70 mm²

* 2 to 34 core - 0,75 mm²
* 2 to 34 core - 2,5 mm²
* 2 to 5 core - 10 mm²
* 3 to 5 core - 35 mm²

* 2 to 34 core - 1,00 mm²
* 2 to 7 core - 4 mm²
* 2 to 5 core - 16 mm²
* 3 to 5 core - 50 mm²

Batch or Serial Number

M1 4 XXX XXYYYYZZZ

Intended use:

YY-YSLY cables are used as supply of electricity and communications in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke to regulations on reaction to fire

System 3

of assessment and verification of constancy of performance

Notified laboratory body No. NB 1014

performed the determination of product type on basis of type testing (based on sampling carried out by the manufacturer), type calculation, tabulated values or descriptive documentation of the product and issued the certificate of constancy of performance. Factory production control (FPC) carried out by the ÜNKABLO as manufacturer

Reaction to fire:

Eca

Harmonized technical
specification

EN 50575 : 2014 / A1:2016
EN 60332-1 & EN 50525-2-51

Dangerous Substances:

NPD

Manufacturer:

ÜNKABLO SAN. VE TİC. A.Ş
Saray Mah.
Ahmet Tevfik İleri Cad.
No : 16/4
Ümraniye / İstanbul / TURKEY

Signed for and behalf of the manufacturer by:

Barış TABAK / QA & QC Manager
İstanbul, 17/02/2017



This declaration of performance is issued under the sole responsibility of the manufacturer.