



ÜNKA KABLO

Declaration of Performances (DoP)

No. 20170013

Product Type

L12YY (300/500 V)

* 2 to 34 core - 0,5 mm²

* 2 to 34 core - 1,5 mm²

* 2 to 5 core - 6 mm²

* 3 to 5 core - 25 mm²

* 3 to 4 core - 70 mm²

* 2 to 34 core - 0,75 mm²

* 2 to 34 core - 2,5 mm²

* 2 to 5 core - 10 mm²

* 3 to 5 core - 35 mm²

* 2 to 34 core - 1,00 mm²

* 2 to 7 core - 4 mm²

* 2 to 5 core - 16 mm²

* 3 to 5 core - 50 mm²

Batch or Serial Number

M1 4 XXX XXYYYYZZZ

Intended use:

L12YY cables are used These PVC cables are used in industrial applications for signal transmission. They can be easily used with their flexible construction in narrow applications like: electronic control systems of computer or audio systems or in communication sector, electronic circuits, measurement devices, machine design, office equipment, etc. They are for indoor applications with the objective of limiting spread of fire and smoke and subject to regulations on reaction to fire

System 3

of assessment and verification of constancy of performance

Notified laboratory body No. NB 1014

performed the determination of product type on basis of type testing (based on sampling carried out by the manufacturer), type calculation, tabulated values or descriptive documentation of the product and issued the certificate of constancy of performance Factory production control (FPC) carried out by the ÜNKA KABLO as manufacturer

Reaction to fire:

Eca

Harmonized technical
specification

EN 50575 : 2014 / A1:2016
EN 60332-1 & DIN VDE 0812

Dangerous Substances:

NPD

Manufacturer:

ÜNKA KABLO SAN. VE TİC. A.Ş

Saray Mah.

Ahmet Tevfik İleri Cad.

No : 16/4

Ümraniye / İstanbul / TURKEY

Signed for and behalf of the manufacturer by:

Barış TABAK / QA & QC Manager

İstanbul, 17/02/2017



This declaration of performance is issued under the sole responsibility of the manufacturer.