

## Declaration of Performances (DoP)

No. UK2021006

Product Type

YSLYCY (300/500 V)

\* 2 to 34 core - 0,5 mm<sup>2</sup>

\* 2 to 34 core - 0,75 mm<sup>2</sup>

\* 2 to 34 core - 1,00 mm<sup>2</sup>

\* 2 to 34 core - 1,5 mm<sup>2</sup>

\* 2 to 34 core - 2,5 mm<sup>2</sup>

\* 2 to 7 core - 4 mm<sup>2</sup>

\* 2 to 5 core - 6 mm<sup>2</sup>

\* 2 to 5 core - 10 mm<sup>2</sup>

\* 2 to 5 core - 16 mm<sup>2</sup>

\* 3 to 5 core - 25 mm<sup>2</sup>

\* 3 to 5 core - 35 mm<sup>2</sup>

\* 3 to 5 core - 50 mm<sup>2</sup>

\* 3 to 4 core - 70 mm<sup>2</sup>

Batch or Serial Number

M1 4 XXX XYYYZZZ

Intended use:

Supply of electricity in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke

### System 3

of assessment and verification of constancy of performance

### Approved laboratory body No. NB 2661

The performance of the product identified above is in conformity with the declared performance(s) This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, as its effect in the United Kingdom under the sole responsibility of the manufacturer identified above.

**Reaction to fire:**

**Eca**

Designated standard:

EN 50575 : 2014 + A1:2016

**Dangerous Substances:**

**NPD**

Manufacturer:

ÜNKA KABLO SAN. VE TİC. A.Ş

Saray Mah.

Ahmet Tevfik İleri Cad.

No : 16/4

Ümraniye / İstanbul / TURKEY

Signed for and behalf of the manufacturer by:

Barış TABAK / QA & QC Manager

İstanbul, 11/08/2021