



ÜNKA KABLO

UK  
CA

## Declaration of Performances (DoP)

No. UK2021010

Product Type

YSLYCY (600/1000 V)

\* 2 to 34 core - 0,5 mm<sup>2</sup>

\* 2 to 34 core - 1,5 mm<sup>2</sup>

\* 2 to 5 core - 6 mm<sup>2</sup>

\* 3 to 5 core - 25 mm<sup>2</sup>

\* 3 to 4 core - 70 mm<sup>2</sup>

\* 2 to 34 core - 0,75 mm<sup>2</sup>

\* 2 to 34 core - 2,5 mm<sup>2</sup>

\* 2 to 5 core - 10 mm<sup>2</sup>

\* 3 to 5 core - 35 mm<sup>2</sup>

\* 2 to 34 core - 1,00 mm<sup>2</sup>

\* 2 to 7 core - 4 mm<sup>2</sup>

\* 2 to 5 core - 16 mm<sup>2</sup>

\* 3 to 5 core - 50 mm<sup>2</sup>

Batch or Serial Number

M1 4 XXX XXYYYYZZZ

Intended use:

Supply of electricity in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke

### System 3

of assessment and verification of constancy of performance

### Approved laboratory body No. NB 2661

The performance of the product identified above is in conformity with the declared performance(s) This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, as its effect in the United Kingdom under the sole responsibility of the manufacturer identified above.

**Reaction to fire:**

**Eca**

**Dangerous Substances:**

**NPD**

Designated standard:  
EN 50575 : 2014 + A1:2016

Manufacturer:  
ÜNKA KABLO SAN. VE TİC. A.Ş  
Saray Mah.  
Ahmet Tevfik İleri Cad.  
No : 16/4  
Ümraniye / İstanbul / TURKEY

Signed for and behalf of the manufacturer by:  
Barış TABAK / QA & QC Manager  
İstanbul, 11/08/2021

  
ÜNKA KABLO  
SANAYİ VE TİCARET A.Ş.  
ÜMRANIYE - İSTANBUL