



ÜNKA KABLO

UK  
CA

## Declaration of Performances (DoP)

No. UK2021023

Product Type

LI2YCYv-TP (300/500 V)

\* 1 PR to 20PR - 0,5 mm<sup>2</sup>

\* 1 PR to 20PR - 0,75 mm<sup>2</sup>

\* 1 PR to 20PR - 1,00 mm<sup>2</sup>

\* 1 PR to 30PR - 1,5 mm<sup>2</sup>

\* 1 PR to 12PR - 2,5 mm<sup>2</sup>

Batch or Serial Number

M1 4 XXX XXYYYYZZ

Intended use:

Supply of electricity in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke

### System 3

of assessment and verification of constancy of performance

### Notified laboratory body No. NB 2822

The performance of the product identified above is in conformity with the declared performance(s) This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Reaction to fire:

**Eca**

Designated standard:

EN 50575 : 2014 + A1:2016

Dangerous Substances:

**NPD**

Manufacturer:  
ÜNKA KABLO SAN. VE TİC. A.Ş  
Organize Sanayi Bölgesi Mah.  
15 Sk. No: 1/3  
Dilovası / Kocaeli / TURKEY

Signed for and behalf of the manufacturer by:  
Barış TABAK / QA & QC Manager  
İstanbul, 20/03/2026

  
**ÜNKA KABLO**  
SANAYİ ve TİCARET A.Ş.  
DİLOVASI - KOCAELİ